



ADDENDUM 01

Project: Sunset Pool Roofing

Addendum Date: December 6, 2023

Bid Document Date: REV. 11/17/23 Park District Bid

This Addendum becomes a part of the Bidding and Contract Documents and modifies the original Bidding Documents. Acknowledgment of receipt of this Addendum in the space provided on the Bid Form is required. FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID FORM MAY DISQUALIFY BID.

General Clarifications:

1. Roof leaks are shown on sheet A1.3, cross hatched with the keynote R4. The underlaying substrate is rotted plywood and needs to be replaced. This is part of base bid and is on the bid form.
2. Current buildings do not have gutters or downspouts, and there are no plans to add them.
3. Ice & Water shield is to be provided over the entire roof.

END OF ADDENDUM